FOR MYSORE STATE

(PUBLIC WORKS) (1955) **Department.**

Ms.
(Ms) **SERIES.**

G.O. No. (2666.) 2666.

Dated (12-7-1955) 12th July 1955.

Supdt
16.7.55.

[Despatch Abstract.]

Electricity - Mangalore Electric Licence - Prevention of unauthorised inc of horse-power - Affixation of name plate and details on motors - Booklet conditions and rates of supply - Part I - Amendment Approved.

Tele:- "KILOVOLTS"

F. 33c-1000

The Mangalore Electric Supply Company, Limited.

MANAGING AGENTS:
Octavius Steel & Co., Ltd.,
CALCUTTA.

Chief Resident Engineer's Office,
POST BOX NO. 78
Mangalore 1.

Ref. No. MAN/ 1410/24

Dated 30th June, *195*

150.

The Secretary to the Government
of Madras, P.W.D.,
Fort St. George,
Madras.

Through -

The Chief Electrical Inspector
to Government,
157, Mount Road,
Madras-2.

Dear Sir, Amendment to booklet of conditions of supply.

I have the honour to inform you that the Chief Electrical Inspector to Government has, in his Circular letter No. 2193.L/55-1 of 14-5-1955, recommended that the undernoted Clause which has been approved by the Government of Madras for adoption in their area may be adopted here also, and the Company has accepted the same.

Accordingly, I herewith apply for adding the Clause as Clause 18(A)(1) of the booklet of Conditions of Supply.

"No electric motor should be used without its manufacturer's name-plate permanently affixed on it. If at the time of effecting supply or during periodical check-inspection by the Licensee, it is found that the name-plate of any motor is missing or does not appear to show the correct capacity of the motor, the Licensee will give due notice in writing to the Consumer to give facilities to him for testing the motor at site or to get the motor tested by the Chief Electrical Inspector to Government to have the H.P. certified and to have a reference number given to it by the Chief Electrical Inspector to Government. If within thirty days of receipt of such notice, the Consumer does not allow the test to be done or get the motor tested by the Chief Electrical Inspector to Government or any one authorised by him and produce a certificate as to the actual capacity

of the motor, the Licensee may refuse to effect suppl the motor, where supply has to be effected for the fi time, or shall cut off supply to the Consumer without further notice where supply is/was existing."

Yours faithfully,

Chief Engineer. 30/6/47

57955

Office of the Chief Electrical Inspec
to Government, 157, Mount Road, Madra



Endorsement No. 2193-L/55-3 dated 7th July, 1955:

Sub :: ELECTRICITY - Mangalore Electric Supply Company - amendment to booklet of conditions of supply-

Ref :: Letter No. MAN/1410/24 dated 30--6--1955. pp 1-3 auto

--

Forwarded to the Secretary to Government, Public Works Department, Fort St. George, Madras.

2. The a-mendment proposed by the licensee is the same as approved in the case of the Ponnamaravathy Electric Supply Corporation Ltd., in G.O. Ms. No. 2449 dated 27--6--1955. As the amendment is in order it may be approved. Go not put up

3. The licensee may be directed to issue printed correction slips and submit three copies each to Government to the Chief Electrical Inspector to Government.

(2) 7/7/55

Chief Electrical Inspector
to Government.

To

The Secretary to Government,
Public Works Department,
Fort St. George.

Electricity - Mangalore Electric licence - Prevention of unauthorised increase of horse-power - Affixation of name plate and details on motors - Booklet of Conditions and rates of Supply - Part I - Amendment - Approved.

Read:

From the Mangalore Electric Supply Co. Ltd. Ref. No. MAN/1410/248 30.6.55

From the Coll. Sudr. No. 2193-I/55-3 & 7.7.55.

G.O. Ms. No. 2666 & 12-7-55.

The Government approve the following amendment to the booklet of Conditions and rates of Supply of the Mangalore Electric Supply Company Limited, the licensee under the Mangalore Electric licence:-

Amendment.

In part I of the booklet, after clause 18A, the following new clause shall be added, namely:-

"18A-(i). H.E. "A" on pp. 1-3 of as edited in pencil."

2. The licensee is requested to issue necessary printed Correction Slips to the booklet of Conditions and rates of Supply of the Mangalore electrical undertaking and submit

three copies each to the Govt.
and the CEIG.

9.7.55.

9.7.55

9/7/55

To.

The Mangalore Electric
Supply Co. Ltd., P.B. No. 78
Mangalore-1.

The C.E.I.G.

Clean copy for file.

I Sec.

Note: Please see the letter from the Mangalore licensee at pp. 1-3 ci. and the Govt. of the CEIG. letter at p. 5 ci. The draft order above is subs. for approval.

DES: I Sec.

Dt.

9.7.55.

9.7.55

(ABSTRACT)

Electricity - Mangalore Electric Licence - Prevention of unauthorise increase of horse-power - Affixation of name plate and details on motors - Booklet of conditions and rates of supply - Part I - Amendme Approved.

PUBLIC WORKS DEPARTMENT

G.O.Ms.No. 2666. Dated 12-7-1955.
Read the following:

From the Mangalore Electric Supply Company Limited Reference No. MAN/ 1410/24 dated 30-6-55.
From the Chief Electrical Inspector to Government Endorsement No. 219 L/55-3 dated 7-7-55.

...

ORDER:

The Government approve the following amendment to the booklet of condition and rates of supply of the Mangalore Electric Supply Company Limited, the licensee under the Mangalore Electric Licence:-

AMENDMENT.

In part I of the booklet, after clause 18A, the followi new clause shall be added, namely:-

"18A-(1). No electric motor should be used without its manufacturer's name-plate permanently affixed on it. If at the time of effecting supply or during periodical check-inspection by the Licensee, it is found that the name-plate of any motor is missing or does not appear to show the correct capacity of the motor, the Licen will give due notice in writing to the Consumer to give facilities to him for testing the motor at site or to get the motor tested by the Chief Electrical Inspector to Government to have the Horse Power certified and to have a reference number given to it by the Chief Electrical Inspector to Government. If within thirty days of receip of such notice, the Consumer does not allow the test to be done or get the motor tested by the Chief Electrical Inspector to Government or any one authorised by him and produce a certificate as to the actual capacity of motor, the Licensee may refuse to effect supply to the motor, where supply has to be effected for the first time, or shall cut off supply to the Consumer without any further notice wher supply was existing."

2. The licensee is requested to issue necessary printe correction slips to the booklet of conditions and rates of supply of the Mangalore electrical undertaking and submit three copies each t the Government and the Chief Electrical Inspector to Government.

(By order of the Governor)

C.P. Kelu Erady,
Deputy Secretary to Government.

To
The Mangalore Electric Supply Corporation Limited, P.B.No.78, Mangalore-1.
The Chief Electrical Inspector to Government.

True Copy /Forwarded/ By order

Tele:- "KILOVOLTS"

F. 32c.

The Mangalore Electric Supply Company Limited.

MANAGING AGENTS:
Octavius Steel & Co., Ltd.,
CALCUTTA.

Chief Resident Engineer's Office,
POST BOX NO. 78
Mangalore-1.

Ref No. MAN/ 1544/24 *Dated 19th July, 195 5.*

02759

ASST. SECRETARY TO GOVERNMENT
25 JUL 1955
PUBLIC WORKS DEPARTMENT

The Secretary to the Government
of Madras, P.W.D.
Fort St. George,
Madras.

Dear Sir, Electricity - Mangalore Electric Licence - prevention of unauthorised increase of horse-power - Affixation of name plate and details on motors - Booklet of conditions and rates of supply - Part I - Amendment.

I am in receipt of your G.O.Ms. No.2666 dated 12-7-1955 approving the amendment in the booklet of Conditions as requested in my letter No. MAN/1410/24 dated 30-6-1955.

2. I send herewith three copies of the slips printed in this connection, as desired.

Yours faithfully,

Chief Engineer.

Encl:-

Copy to: The Chief Electrical Inspector to Govt., Madras, together with three copies of the printed slips referred to above.

THE MANGALORE ELECTRIC SUPPLY CO. LTD.

CONDITIONS OF SUPPLY

In Part I of the existing booklet at Page 6, add the following as Clause 18 (A) 1:-

"No electric motor should be used without its manufacturer's name-plate permanently affixed on it. If at the time of effecting supply or during periodical check-inspection by the Licensee it is found that the name-plate of any motor is missing or does not appear to show the correct capacity of the motor, the Licensee will give due notice in writing to the consumer to give facilities to him for testing the motor at site or to get the motor tested by the Chief Electrical Inspector to Government, to have the H. P. certified and to have a reference number given to it by the Chief Electrical Inspector to Government. If within thirty days of receipt of such notice the Consumer does not allow the test to be done or get the motor tested by the Chief Electrical Inspector to Government or any one authorised by him and produce a certificate as to the actual capacity of the motor, the Licensee may refuse to effect supply to the motor, where supply has to be effected for the first time or shall cut off supply to the Consumer without any further notice where supply is existing."

(Approved by the Government of Madras, vide Circular letter No.2193.L/55-1, dated 14—5—'55, issued by the Chief Electrical Inspector, Madras.)

(G.O.Ms.No. 2666 dated 12-7-1955)

Same as p. 3 ante 15

THE MANGALORE ELECTRIC SUPPLY CO. LTD.

CONDITIONS OF SUPPLY

In Part I of the existing booklet at Page 6, add the following as Clause 18 (A) 1:-

"No electric motor should be used without it manufacturer's name-plate permanently affixed on it. If a the time of effecting supply or during periodical check inspection by the Licensee it is found that the name-plat of any motor is missing or does not appear to show th correct capacity of the motor, the Licensee will give du notice in writing to the consumer to give facilities to him fo testing the motor at site or to get the motor tested by th Chief Electrical Inspector to Government, to have the H. P certified and to have a reference number given to it by th Chief Electrical Inspector to Government. If within thirt days of receipt of such notice the Consumer does not allo the test to be done or get the motor tested by the Chie Electrical Inspector to Government or any one authorised b him and produce a certificate as to the actual capacity o the motor, the Licensee may refuse to effect supply to th motor, where supply has to be effected for the first time o shall cut off supply to the Consumer without any furthe notice where supply is existing."

(Approved by the Government of Madras, vide Circula letter No.2193.L/55-1, dated 14—5—'55, issued by the Chie Electrical Inspector, Madras.)

(G.O.Ms.No. 2666 dated 12-7-1955)